

946.12 MAINTENANCE AND FINAL INSPECTION APPROVAL.

946.12 MAINTENANCE AND FINAL INSPECTION APPROVAL.

Document type	section
Identifier	946.12
Citation	§ 946.12
Ordinances detected	S, 116-84, INANCE, ER, INARY, ERED, 25-11, ERS
Original source	American Legal Publishing
Content hash	ac4b2eb6b991578cf4846c93794a6195779a8383beec6efe77c1489dad80ddc8

CODIFIED ORDINANCES OF THE CITY OF SHEFFIELD LAKE, OHIO

CERTIFICATION

ROSTER OF OFFICIALS

ADOPTING ORDINANCE NO. 116-84

COMPARATIVE SECTION TABLE

TABLES OF SPECIAL ORDINANCES OF SHEFFIELD LAKE

CHARTER

PART ONE - ADMINISTRATIVE CODE

PART THREE - TRAFFIC CODE

PART FIVE - GENERAL OFFENSES CODE

PART SEVEN - BUSINESS REGULATION CODE

PART NINE - STREETS, UTILITIES AND PUBLIC SERVICES CODE

TITLE ONE - Street and Sidewalk Areas

TITLE THREE - Public Utilities

CHAPTER 931 Sewers

CHAPTER 935 Water

CHAPTER 939 Notice to Purchasers of Status of Utility Accounts

CHAPTER 943 Stormwater

CHAPTER 944 Illicit Discharge and Illegal Connection Control

CHAPTER 945 Construction Site Runoff Control

CHAPTER 946 Post-Construction Storm Water Management

946.01 PURPOSE AND SCOPE.

946.02 DEFINITIONS.

946.03 DISCLAIMER OF LIABILITY.

946.04 CONFLICTS, SEVERABILITY, NUISANCES AND RESPONSIBILITY.

946.05 DEVELOPMENT OF COMPREHENSIVE STORM WATER MANAGEMENT PLANS.

946.06 APPLICATION PROCEDURES.

946.07 COMPLIANCE WITH STATE AND FEDERAL REGULATIONS.

946.08 COMPREHENSIVE STORM WATER MANAGEMENT PLANS.

946.09 PERFORMANCE STANDARDS.

946.10 ALTERNATIVE ACTIONS.

946.11 EASEMENTS.

946.12 MAINTENANCE AND FINAL INSPECTION APPROVAL.

946.13 ON-GOING INSPECTIONS.

946.14 FEES.

946.15 BOND.

946.16 INSTALLATION OF WATER QUALITY BEST MANAGEMENT PRACTICES.

946.17 VIOLATIONS.

946.18 APPEALS.

946.99 PENALTY.

TITLE FIVE - Other Public Services

PART ELEVEN - PLANNING AND ZONING CODE

PART THIRTEEN - BUILDING CODE

PART FIFTEEN - FIRE PREVENTION CODE

OH

Sheffield Lake

(a) General: The storm water system, including storm water management practices for storage, treatment and control, and conveyance facilities, shall be designed to prevent structure flooding during the 100-year, 24-hour storm event; to maintain predevelopment runoff patterns, flow, and volumes; and to meet the following criteria;

(1) Integrated practices that address degradation of water resources. The storm water management practices shall function as an integrated system that controls flooding and minimizes the degradation of the physical, biological, and chemical integrity of the water resources receiving storm water discharges from the site. Acceptable practices shall:

A. Not disturb riparian areas, unless the disturbance is intended to support a watercourse restoration project and complies with Chapter 944.

B. Maintain predevelopment hydrology and groundwater recharge on as much of the site as practicable.

C. Only install new impervious surfaces and compact soils where necessary to support the future land use.

D. Compensate for increased runoff volumes caused by new impervious surfaces and soil compaction by reducing storm water peak flows to less than predevelopment levels. Storm water management practices that meet the criteria in this regulation, and additional criteria required by the Service Director, shall comply with this regulation.

(2) Practices designed for final use: Storm water management practices shall be designed to achieve the storm water management objectives of this regulation, to be compatible with the proposed post-construction use of the site, to protect the public health, safety, and welfare, and to function safely with minimal maintenance.

(3) Storm water management for all lots: Areas developed for a subdivision, as defined in Chapter 1162 of the Codified Ordinance, shall provide storm water management and water quality controls for the development of all subdivided lots. This shall include provisions for lot grading and drainage that prevent structure flooding during the 100-year, 24-hour storm; and maintain, to the extent practicable, the pre-development runoff patterns, volumes, and peaks from the lot.

(4) Storm water facilities in water resources: Storm water management practices and related activities shall not be constructed in water resources unless the applicant shows proof of compliance with all appropriate permits from the Ohio EPA, the U.S. Army Corps, and other applicable federal, state, and local agencies as required in Section 946.07 of this regulation, and the activity is in compliance with Chapter 944 and Chapter 945, all as determined by the Service Director.

(5) Storm water ponds and surface conveyance channels: All storm water pond and surface conveyance designs must provide a minimum of one (1) foot freeboard above the projected peak stage within the facility during the 100-year, 24-hour storm. When designing storm water ponds and conveyance channels, the applicant shall consider public safety as a design factor and alternative designs must be implemented where site limitations would preclude a safe design.

(6) Exemption: The site where soil-disturbing activities are conducted shall be exempt from the requirements of Section 946.09 if it can be shown to the satisfaction of the Service Director that the site is part of a larger common plan of development where the storm water management requirements for the site are provided by an existing storm water management practice, or if the

storm water management requirements for the site are provided by practices defined in a regional or local storm water management plan approved by the Service Director.

(7) Maintenance: All storm water management practices shall be maintained in accordance with Inspection and Maintenance Agreements approved by the Service Director as detailed in Section 946.08.

(8) Ownership: Unless otherwise required by the City of Sheffield Lake, storm water management practices serving multiple lots in subdivisions shall be on a separate lot held and maintained by an entity of common ownership or, if compensated by the property owners, by the City of Sheffield Lake. Storm water management practices serving single lots shall be placed on these lots, protected within an easement, and maintained by the property owner.

(9) Preservation of Existing Natural Drainage. Practices that preserve and/or improve the existing natural drainage shall be used to the maximum extent practicable. Such practices may include minimizing site grading and compaction; protecting and/or restoring water resources, riparian areas, and existing vegetation; and maintaining unconcentrated storm water runoff to and through these areas.

(10) Preservation of Wetland Hydrology: Concentrated storm water runoff from BMPs to wetlands shall be converted to diffuse flow before the runoff enters a wetland in order to protect the natural hydrology, hydroperiod, and wetland flora. The flow shall be released such that no erosion occurs down slope. Practices such as level spreaders, vegetative buffers, infiltration basins, conservation of forest covers, and the preservation of intermittent streams, depressions, and drainage corridors may be used to maintain the wetland hydrology.

If the applicant proposes to discharge to natural wetlands, a hydrological analysis shall be preformed to demonstrate that the proposed discharge matches the pre-development hydroperiods and hydrodynamics.

(b) Storm Water Conveyance Design Criteria: All storm water management practices shall be designed to convey storm water to allow for the maximum removal of pollutants and reduction in flow velocities. This shall include but not be limited to:

(1) Stream relocation or enclosure: The Service Director may allow the enclosure or relocation of water resources only if the applicant shows proof of compliance with all appropriate permits from the Ohio EPA, the U.S. Army Corps, and other applicable federal, state, and local agencies as required in Section 946.07 of this regulation, and the activity is in compliance with Chapter 944 and Chapter 945, all as determined by the Service Director. At a minimum, stream relocation designs must show how the project will minimize changes to the vertical stability, floodplain form, channel form, and habitat of upstream and downstream channels on and off the property.

(2) Off-site storm water discharges: Off-site storm water runoff that discharges to or across the applicant's development site shall be conveyed through the storm water conveyance system planned for the development site at its existing peak flow rates during each design storm. Off-site flows shall be diverted around storm water quality control facilities or, if this is not possible, the storm water quality control facility shall be sized to treat the off-site flow. Comprehensive Storm Water Management Plans will not be approved until it is demonstrated to the satisfaction of the Service Director that off-site runoff will be adequately conveyed through the development site in a manner that does not exacerbate upstream or downstream flooding and erosion.

(3) Sheet flow. The site shall be graded in a manner that maintains sheet flow over as large an area as possible. The maximum area of sheet flow shall be determined based on the slope, the uniformity of site grading, and the use of easements or other legally-binding mechanisms that prohibit re-grading and/or the placement of structures within sheet flow areas. In no case shall the

sheet flow length be longer than 300 feet, nor shall a sheet flow area exceed 1.5 acres. Flow shall be directed into an open channel, storm sewer, or other storm water management practice from areas too long and/or too large to maintain sheet flow, all as determined by the Service Director.

(4) Open channels: Unless otherwise allowed by the Service Director, drainage tributary to storm water management practices shall be provided by an open channel with landscaped banks and designed to carry the 10-year, 24-hour storm water runoff from upstream contributory areas.

(5) Open drainage systems: Open drainage systems shall be preferred on all new development sites to convey storm water where feasible. Storm sewer systems shall be allowed only when the site cannot be developed at densities allowed under Sheffield Lake's zoning or where the use of an open drainage system affects public health or safety, all as determined by the Service Director. The following criteria shall be used to design storm sewer systems when necessary:

A. Storm sewers shall be designed such that they do not surcharge from runoff caused by the 5-year, 24 hour storm, and that the hydraulic grade line of the storm sewer stays below the gutter flow line of the overlying roadway, or below the top of drainage structures outside the roadway during a 10-year, 24-hours storm. The system shall be designed to meet the requirements when conveying the flows from the contributory area within the proposed development and existing flows from offsite areas that are upstream from the development.

B. The minimum inside diameter of pipe to be used in public storm sewer systems is 12 inches. Smaller pipe sizes may be used in private systems, subject to the approval of the Service Director.

C. All storm sewer systems shall be designed taking into consideration the tailwater of the receiving facility or water resource. The tailwater elevation used shall be based on the design storm frequency. The hydraulic grade line for the storm sewer system shall be computed with consideration for the energy losses associated with entrance into and exit from the system, friction through the system, and turbulence in the individual manholes, catch basins, and junctions within the system.

D. The inverts of all curb inlets, manholes, yard inlets, and other structures shall be formed and channelized to minimize the incidence of quiescent standing water where mosquitoes may breed.

E. Headwalls shall be required at all storm sewer inlets or outlets to and from open channels or lakes.

(6) Water Resource Crossings. The following criteria shall be used to design structures that cross a water resource in the City of Sheffield Lake.

A. Water resource crossings other than bridges shall be designed to convey the stream's flow for the minimum 25-year, 24-hour storm.

B. Bridges, open bottom arch or spans are the preferred crossing technique and shall be considered in the planning phase of the development. Bridges and open spans should be considered for all State Scenic Rivers, coldwater habitat, exceptional warmwater habitat, seasonal salmonid habitat streams, and Class III headwater streams. The footers or piers for these bridges and open spans shall not be constructed below the ordinary high water mark.

C. If a culvert or other closed bottom crossing is used, twenty-five (25) percent of the cross-sectional area or a minimum of 1 foot of box culverts and pipe arches must be embedded below the channel bed.

D. The minimum inside diameter of pipes to be used for crossings shall be 12 inches.

E. The maximum slope allowable shall be a slope that produces a 10-fps velocity within the

culvert barrel under design flow conditions. Erosion protection and/or energy dissipaters shall be required to properly control entrance and outlet velocities.

F. All culvert installations shall be designed with consideration for the tailwater of the receiving facility or water resource. The tailwater elevation used shall be based on the design storm frequency.

G. Headwalls shall be required at all culvert inlets or outlets to and from open channels or lakes.

H. Streams with a drainage area of 5 square miles or larger shall incorporate floodplain culverts at the bankfull elevation to restrict head loss differences across the crossing so as to cause no rise in the 100-year storm event.

I. Bridges shall be designed such that the hydraulic profile through a bridge shall be below the bottom chord of the bridge for either the 100-year, 24-hour storm, or the 100-year flood elevation as determined by FEMA, whichever is more restrictive.

(7) Overland flooding: Overland flood routing paths shall be used to convey storm water runoff from the 100-year, 24-hour storm event to an adequate receiving water resource or storm water management practice such that the runoff is contained within the drainage easement for the flood routing path and does not cause flooding of buildings or related structures. The peak 100-year water surface elevation along flood routing paths shall be at least one foot below the finished grade elevation at the structure. When designing the flood routing paths, the conveyance capacity of the site's storm sewers shall be taken into consideration.

(8) Compensatory flood storage mitigation: In order to preserve floodplain storage volumes and thereby avoid increases in water surface elevations, any filling within floodplains approved by the City of Sheffield Lake must be compensated by removing an equivalent volume of material.

First consideration for the location(s) of compensatory floodplain volumes should be given to areas where the stream channel will have immediate access to the new floodplain within the limits of the development site. Consideration will also be given to enlarging existing or proposed retention basins to compensate for floodplain fill if justified by a hydraulic analysis of the contributing watershed. Unless otherwise permitted by the City of Sheffield Lake, reductions in volume due to floodplain fills must be mitigated within the legal boundaries of the development. Embankment slopes used in compensatory storage areas must reasonably conform to the natural slopes adjacent to the disturbed area. The use of vertical retaining structures is specifically prohibited.

(9) Velocity dissipation: Velocity dissipation devices shall be placed at discharge locations and along the length of any outfall to provide non-erosive flow velocity from the structure to a water resource so that the natural physical and biological characteristics and functions of the water resource are maintained and protected

(c) Storm Water Quality Control:

(1) Direct runoff to a BMP: The site shall be designed to direct runoff to one or more of the following storm water management practices. These practices are listed in Table 2 of this regulation and shall be designed to meet the following general performance standards:

A. Extended conveyance facilities that slow the rate of storm water runoff; filter and biodegrade pollutants in storm water; promote infiltration and evapotranspiration of storm water; and discharge the controlled runoff to a water resource.

B. Extended detention facilities that detain storm water; settle or filter particulate pollutants; and release the controlled storm water to a water resource.

C. Infiltration facilities that retain storm water; promote settling, filtering, and

biodegradation of pollutants; and infiltrate captured storm water into the ground. The Sheffield Lake engineer may require a soil engineering report to be prepared for the site to demonstrate that any proposed infiltration facilities meet these performance standards.

D. For sites less than five (5) acres, but greater than one (1) acre and not part of a common plan of development, where (1) or more acres are disturbed, the Sheffield Lake Engineer may approve other BMPs if the applicant demonstrates to the Sheffield Lake Engineer's satisfaction that these BMPs meet the objectives of this regulation as stated in Section 946.09(C)(6)

E. For sites greater than five (5) acres, or less than five (5) acres but part of a larger common plan of development for sale which will disturb five (5) or more acres, the Sheffield Lake Engineer may approve other BMPs if the applicant demonstrates to the Sheffield Lake Engineer's satisfaction that these BMPs meet the objectives of this regulation as stated in Section 946.09(C)(6) and has prior written approval from the Ohio EPA.

F. For the construction of new roads and roadway improvement projects by public entities (i.e. the state, counties, townships, cities, or villages), the Sheffield Lake Engineer may approve BMPs not included in Table 2 of this regulation, but must show compliance with the current version of the Ohio Departments of Transportation "Location and Design Manual, Volume Two Drainage Design".

(2) Criteria applying to all storm water management practices. Practices chosen must be sized to treat the water quality volume (WQv) and to ensure compliance with Ohio Water Quality Standards (OAC Chapter 3745-1).

A. The WQv shall be equal to the volume of runoff from a 0.75 inch rainfall event and shall be determined according to one of the following methods:

1. Through a site hydrologic study approved by the Sheffield Lake Engineer that uses continuous hydrologic simulation; site-specific hydrologic parameters, including impervious area, soil infiltration characteristics, slope, and surface routing characteristics; proposed best management practices controlling the amount and/or timing of runoff from the site; and local long-term hourly records, or

2. Using the following equation:

$$WQv = C \cdot P \cdot A / 12$$

Where terms have the following meanings:

WQv = water quality volume in acre-feet

C = runoff coefficient appropriate for storms less than 1 in.

P = 0.75 inch precipitation depth

A = area draining into the storm water practice, in acres.

Runoff coefficients required by the Ohio Environmental Protection Agency (Ohio EPA) for use in determining the water quality volume can be determined using the list in Table 1 or using the following equation to calculate the runoff coefficient, if the applicant can demonstrate that appropriate controls are in place to limit the proposed impervious area of the development:

$$C = 0.858i^3 - 0.78i^2 + 0.774i + 0.04, \text{ where:}$$

i = fraction of the drainage area that is impervious

Table 1: Runoff Coefficients Based on the Type of Land Use

Land Use

Runoff Coefficient

Industrial & Commercial

0.8

High Density Residential (>8 dwellings/acres)

0.5

Medium Density Residential (4 to 8 dwellings/acre)

0.4

Low Density Residential (<4 dwellings/acre)

0.3

Open Space and Recreational Areas

0.2

Where land use will be mixed the runoff coefficient should be calculated using a weighted average. For example, if 60% of the contributing drainage area to the storm water treatment structure is Low Density Residential, 30% is High Density Residential, and 10% is Open Space, the runoff coefficient is calculated as follows $(0.6)(0.3)+(0.3)(0.5)+(0.1)(0.2)=(0.35)$

B. An additional volume equal TO 20% of the WQv shall be incorporated into the storm water practice for sediment storage. This volume shall be incorporated into the sections of storm water practices where pollutants will accumulate.

C. Storm water quality management practices shall be designed such that the drain time is long enough to provide treatment and protect against downstream bank erosion, but short enough to provide storage available for successive rainfall events as defined in Table 2.

Table 2: Draw Down Times for Storm Water Management Practices

Best Management Practice

Drain Time of WQv

Infiltration Facilities*

24-48 hours

Extended Conveyance Facilities
(Vegetated Swales, Filter Strips)

24 hours

- Vegetated Filter Strip with Berm
- Enhanced Water Quality Swale
- Flow Through Design

24 hours

**

Extended Detention Facilities

- Extended Dry Detention basins***
- Wet Detention Basins +
- Pocket Wetland
- Construction Wetlands (above permanent pool)
- Bioretention*
- Sand and other Media Filtration

48 hours

24 hours

24 hours

24 hours

40 hours

40 hours

* The WQv shall completely infiltrate within 48 hours so there is no standing or residual water pool.

** Sized to pass a hydrograph with a volume equal to the WQv, a duration of 2 hours, peak rainfall intensity of 1 inch/hour at a depth of no more than 3 inches and have a minimum hydraulic residence time of 5 minutes. The use of this criterion is limited to sites where the total area disturbed is 5 acres or less. Prior approval from the Sheffield Lake Engineer is necessary to use this practice. For sites greater than five (5) acres or less than five (5) acres but part of a larger common plan of development or sale which will disturb five (5) or more acres, prior written approval is required from the Ohio EPA.

*** The use of a forebay and micropool is required on all extended dry detention basins. Each is to be sized at a minimum 10% of the WQv.

+ Provide both a permanent pool and an extended detention volume above the permanent pool, each sized with at least 0.75*WQv.

^ Pocket wetland must have a wet pool equal to the WQv, with 25% of the WQv in a pool and 75% in marshes. The EDV above the permanent pool must be equal to the WQv.

NOTE: This table is similar to that found in the Ohio EPA Construction General Permit. It has been re-ordered to match CRWP's recommended BMP categories and additional description of the "drain time" for vegetated swales and filter strips has been added. The "Flow Through Design" BMP is an Ohio EPA alternative practice and does require additional approvals from the Community Engineer and Ohio EPA depending the development site size, and can be removed from the table if necessary.

D. Each practice shall be designed to facilitate sediment removal, vegetation management, debris control, and other maintenance activities defined in the Inspection and Maintenance Agreement for the site.

(3) Additional criteria applying to infiltration facilities.

A. Infiltration facilities shall only be allowed if the soils of the facility fall within hydrologic soil groups A or B, if the seasonal high water table is at least three (3) feet below the final grade elevation, and any underlying bedrock is at least six feet below the final grade elevation.

B. All runoff directed into an infiltration basin must first flow through a pretreatment practice such as a grass channel or filter strip to remove coarser sediments that could cause a loss of infiltration capacity.

C. During construction, all runoff from disturbed areas of the site shall be diverted away from the proposed infiltration basin site. No construction equipment shall be allowed within the infiltration basin site to avoid soil compaction.

(4) Additional criteria applying to extended conveyance facilities.

A. Facilities shall be lined with fine turf-forming, flood tolerant grasses.

B. Facilities designed according to the extended conveyance detention design drain time shall:

1. Not be located in areas where the depth to bedrock and/or seasonal high water table is less than 3 feet below the final grade elevation.

2. Only be allowed where the underlying soil consists of hydrologic soil group (HSG) A or B, unless the underlying soil is replaced by at least a 2.5 foot deep layer of soil amendment with a permeability equivalent to a HSG A or B soil and an underdrain system is provided.

C. Facilities designed according to the flow through design drain time shall:

1. Only be allowed on sites where:

a. The total disturbed is 5 acres or less

b. The discharge rate from the BMP will have negligible hydrologic impacts to received waters as described in Section 946.09(C)(6)(b)

c. Prior written approval is given by the Sheffield Lake Engineer; and

d. For sites greater than five (5) acres or less than five (5) acres but part of a larger common plan of development or sale which will disturb five (5) or more acres, prior written approval has been given by the Ohio EPA.

2. Be designed to slow and filter runoff flowing through the turf grasses with a maximum depth of flow no greater than 3 inches.

3. Be designed to have a minimum hydraulic residence time of 5 minutes.

D. Concentrated runoff shall be converted to sheet flow, or a diffuse flow using a plunge pool, flow diffuser or level spreader, before entering an extended conveyance facility designed according to the flow through drain time.

(5) Additional criteria for extended detention facilities:

A. The outlet shall be designed to not release more than the first half of the water quality volume in less than 1/3rd of the drain time. A valve shall be provided to drain any permanent pool volume for removal of accumulated sediments. The outlet shall be designed to minimize clogging, vandalism, maintenance, and promote the capture of floatable pollutants.

B. The basin design shall incorporate the following features to maximize multiple uses, aesthetics, safety, and maintainability:

1. Basin side slopes above the permanent pool shall have a run to rise ratio of 4:1 or flatter.

2. The perimeter of all permanent pool areas deeper than 4 feet shall be surrounded by an aquatic bench that extends at least 8 feet and no more than 15 feet outward from the normal water edge. The 8 feet wide portion of the aquatic bench closest to the shoreline shall have an

average depth of 6 inches below the permanent pool to promote the growth of aquatic vegetation. The remainder of the aquatic bench shall be no more than 15 inches below the permanent pool to minimize drowning risk to individuals who accidentally or intentionally enter the basin, and to limit growth of dense vegetation in a manner that allows waves and mosquito predators to pass through the vegetation. The maximum slope of the aquatic bench shall be 10 (H) to 1 (V). The aquatic bench shall be planted with hearty plants comparable to wetland vegetation that are able to withstand prolonged inundation.

3. A forebay designed to allow larger sediment particles to settle shall be placed at basin inlets. The forebay and micropool volume shall be equal to at least 10% of the water quality volume (WQv).

Note: The section below identifies the criteria that are currently being used by the Ohio EPA to assess the equivalency of alternative practices that are not listed in Table 2. This section can be modified to meet the needs of the Community.

(6) Criteria for the Acceptance of Alternative post-construction BMPs: The applicant may request approval from the Sheffield Lake Engineer for the use of alternative structural post-construction BMPs if the applicant shows to the satisfaction of the Sheffield Lake Engineer that these BMPs are equivalent in pollutant removal and runoff flow/volume reduction effectiveness to those listed in Table 2. If the site is greater than five (5) acres, or less than five (5) acres but part of a larger common plan of development or sale which will disturb five (5) or more acres, prior approval from the Ohio EPA is necessary. To demonstrate the equivalency, the applicant must show:

A. The alternative BMP has a minimum total suspended solid (TSS) removal efficiency of 80 percent, using the Level II Technology Acceptance Reciprocity Partnership (TARP) testing protocol.

B. The water quality volume discharge rate from the selected BMP is reduced to prevent stream bed erosion, unless there will be negligible hydrologic impact to the receiving surface water of the State. The discharge rate from the BMP will have negligible impacts if the applicant can demonstrate one of the following conditions:

1. The entire water quality volume is recharged to groundwater.

2. The development will create less than one acre of impervious surface.

3. The development project is a redevelopment project with an ultra-urban setting, such as a downtown area, or on a site where 100 percent of the project area is already impervious surface and the storm water discharge is directed into an existing storm sewer system.

4. The storm water drainage system of the development discharges directly into a large river of fourth order or greater or to a lake, and where the development area is less than 5 percent of the water area upstream of the development site, unless a Total Maximum Daily Load (TMDL) has identified water quality problems in the receiving surface water of the State.

(d) Storm Water Quantity Control: The comprehensive Storm Water Management Plan shall describe how the proposed storm water management practices are designed to meet the following requirements for storm water quantity control for each watershed in the development:

(1) The peak discharge rate of runoff from the Critical Storm and all more frequent storms occurring under post-development conditions shall not exceed the peak discharge rate of runoff from a 1-year, 24-hour storm occurring on the same development drainage area under pre-development conditions.

(2) Storms of less frequent occurrence (longer return periods) than the Critical Storm, up to the 100-year, 24-hour storm shall have peak runoff discharge rates no greater than the peak runoff rates from equivalent size storms under pre-development conditions. The 1, 2, 5, 10, 25, 50, and

100-year storms shall be considered in designing a facility to meet this requirement.

(3) The Critical Storm for each specific development drainage area shall be determined as follows:

A. Determine, using a curve number-based hydrologic method that generates hydrographs, or other hydrologic method approved by the Sheffield Lake Engineer, the total volume (acre-feet) or runoff from a 1-year, 24-hour storm occurring on the development drainage area before and after development. These calculations shall meet the following standards:

- 1. Calculations shall include the lot coverage assumptions used for full build out as proposed.
- 2. Calculations shall be based on the entire contributing watershed to the development area.
- 3. Curve numbers for the pre-development condition must reflect the average type of land use over the past 10 years and not only the current land use.
- 4. To account for future post-construction improvements to the site, calculations shall assume an impervious surface such as asphalt or concrete for all parking areas and driveways, regardless of the surface proposed in the site description.

B. From the volume determined in Section 946.09(d)(3)A., determine the percent increase in volume of runoff due to development. Using the percentage, select the 24-hour Critical Storm from Table 3.

Table 3: 24-Hour Critical Storm

If the Percentage of Increase in Volume of Runoff is:

The Critical Storm Will be:

Equal to or Greater than:

and Less Than:

10	
1 year	
10	
20	
2 years	
20	
50	
5 years	
50	

100

10 years

100

250

25 years

250

500

50 years

500

100 years

(e) Storm Water Management on Redevelopment Projects: Comprehensive Storm Water Management Plans for redevelopment projects shall reduce existing site impervious areas by at least 20 percent. A one-for-one credit towards the 20 percent net reduction of impervious area can be obtained through the use of pervious pavement and/or green roofs.

(1) Where site conditions prevent the reduction of impervious area, stormwater management practices shall be implemented to provide storm water quality control facilities for at least 20 percent of the site's impervious area.

(2) When a combination of impervious area reduction and storm water quality control facilities are used, the combined area shall equal or exceed 20 percent of the site.

(3) Where projects are a combination of new development and redevelopment, the total water quality volume that must be treated shall be calculated by a weighted average based on acreage, with the new development at 100 percent water quality volume and redevelopment at 20 percent.

(4) Where conditions prevent impervious area reduction or on-site stormwater management for redevelopment projects, practical alternatives as detailed in Section 946.10 may be approved by the Sheffield Lake Engineer.

(Ord. 25-11. Passed 5-24-11.)

946.10 ALTERNATIVE ACTIONS.

(a) When the City of Sheffield Lake determines that site constraints compromise the intent of this regulation, off-site alternatives may be used that result in an improvement of water quality and a reduction of storm water quantity. Such alternatives shall meet the following standards.

(1) Shall achieve the same level of storm water quantity and quality control that would be achieved by the on-site controls required under this regulation.

(2) Implemented in the same Hydrologic Unit Code (HUC) 14 watershed unit as the proposed development project.

(3) The mitigation ratio of the water quality volume is 1.5 to 1 or the water quality volume at

the point of retrofit, whichever is greater.

(4) An inspection and maintenance agreement as described in Chapter 946.08(d)(10) is established to ensure operations and treatment in perpetuity.

(5) Obtain prior written approval from Ohio EPA.

(b) Alternative actions may include, but are not limited to the following. All alternative actions shall be approved by the Sheffield Lake Engineer.

(1) Fees, in an amount specified by the City of Sheffield Lake to be applied to community-wide storm water management practices.

(2) Implementation of off-site storm water management practices and/or the retrofit of an existing practice to increase quality and quantity control.

(3) Stream, floodplain, or wetland restoration.

(4) Acquisition or conservation easements on protected open space significantly contributing to storm water control such as wetland complexes.

(Ord. 25-11. Passed 5-24-11.)

946.11 EASEMENTS.

(a) Easements shall be included in the Inspection and Maintenance Agreement submitted with the Comprehensive Storm Water Management Plan.

(b) Easements shall be approved by the City of Sheffield Lake prior to approval of a final plat and shall be recorded with the Lorain County Auditor and on all property deeds.

(c) Unless otherwise required by the Sheffield Lake Engineer, access easements between a public right-of-way and all storm water management practices shall be no less than 25-feet wide. The easement shall also incorporate the entire practice plus an additional 25-foot wide band around the perimeter of the storm water management practice.

(d) The easement shall be graded and/or stabilized as necessary to allow maintenance equipment to access and manipulate around and within each facility, as defined in the Inspection and Maintenance Agreement for the site.

(e) Easements to structural storm water management practices shall be restricted against the construction therein of buildings, fences, walls, and other structures that may obstruct the free flow of storm water and the passage of inspectors and maintenance equipment; and against the changing of final grade from that described by the final grading plan approved by the City of Sheffield Lake. Any re-grading and/or obstruction placed within a maintenance easement may be removed by the City of Sheffield Lake at the property owners' expense.

(Ord. 25-11. Passed 5-24-11.)

946.12 MAINTENANCE AND FINAL INSPECTION APPROVAL.

To receive final inspection and acceptance of any project, or portion thereof, the following must be completed and provided to the Sheffield Lake Engineer:

(a) Final stabilization must be achieved and all permanent storm water management practices must be installed and made functional, as determined by the Sheffield Lake Engineer and per the approved Comprehensive Storm Water Management Plan.

(b) An As-Built Certification, including a Survey and Inspection, must be sealed, signed and dated by a Professional Engineer and a Professional Surveyor with a statement certifying that the storm water management practices, as designed and installed, meet the requirements of the Comprehensive Storm Water Management Plan approved by the Sheffield Lake Engineer. In evaluating this certification, the Sheffield Lake Engineer may require the submission of a new set of storm water practice calculations if he/she determines that the design was altered significantly from the approved Comprehensive Storm Water Management Plan. The As-Built Survey must

provide the location, dimensions, and bearing of such practices and include the entity responsible for long-term maintenance as detailed in the Inspection and Maintenance Agreement.

(c) A copy of the complete and recorded Inspection and Maintenance Agreement as specified in Section 946.08 must be provided to the Sheffield Lake Engineer.

(Ord. 25-11. Passed 5-24-11.)

946.13 ON-GOING INSPECTIONS.

The City of Sheffield Lake shall inspect storm water management practices periodically. Upon finding a malfunction or other need for maintenance, the City of Sheffield Lake shall provide written notification to the responsible party, as detailed in the Inspection and Maintenance Agreement, of the need for maintenance. Upon notification, the responsible party shall have five (5) working days, or other mutually agreed upon time, to make repairs or submit a plan with detailed action items and established timelines. Should repairs not be made within this time, or a plan approved by the Sheffield Lake engineer for these repairs not be in place, the City of Sheffield Lake may undertake the necessary repairs and assess the responsible party.

(Ord. 25-11. Passed 5-24-11.)

946.14 FEES.

The Comprehensive Storm Water Management Plan review, filing, and inspection fee is part of a complete submittal and is required to be submitted to the City of Sheffield Lake before the review process begins. The Sheffield Lake Engineer shall establish a fee schedule based upon the actual estimated cost for providing these services.

(Ord. 25-11. Passed 5-24-11.)

946.15 BOND.

(a) If a Comprehensive Storm Water Management Plan is required by this regulation, soil-disturbing activities shall not be permitted until a cash bond of 5% of the total project cost, has been deposited with the Sheffield Lake Finance Department. This bond shall be posted for the City of Sheffield Lake to perform the obligations otherwise to be performed by the owner of the development area as stated in this regulation and to allow all work to be performed as needed in the event that the applicant fails to comply with the provisions of this regulation. The stormwater bond will be returned when the following three criteria are met:

(1) After 80% of the lots of the project have been complete or 100% of the total project has been permanently stabilized or three (3) years from the time of permanent stabilization have passed.

(2) An As Built Inspection of all water quality practices is conducted by the Sheffield Lake Engineer.

(3) An Inspection and Maintenance Agreement signed by the developer, the contractor, the City of Sheffield Lake, and the private owner or homeowners association who will take long term responsibility for these BMPs, is accepted by the Sheffield Lake Engineer.

(b) Once these criteria are met, the applicant shall be reimbursed all bond monies that were not used for any part of the project. If all of these criteria are not met after three years of permanent stabilization of the site, the City of Sheffield Lake may use the bond monies to fix any outstanding issues with all storm water management structures on the site and the remainder of the bond shall be given to the private lot owner/homeowners association for the purpose of long term maintenance of the project.

(Ord. 25-11. Passed 5-24-11.)

946.16 INSTALLATION OF WATER QUALITY BEST MANAGEMENT PRACTICES.

The applicant may not direct runoff through any water quality structures or portions thereof that

would be degraded by construction site sediment until the entire area tributary to the structure has reached final stabilization as determined by the Sheffield Lake Engineer. This occurs after the completion of the final grade at the site, after all of the utilities are installed, and the site is subsequently stabilized with vegetation or other appropriate methods. The developer must provide documentation acceptable to the Sheffield Lake Engineer to demonstrate that the site is completely stabilized. Upon this proof of compliance, the water quality structure(s) may be completed and placed into service. Upon completion of installation of these practices, all disturbed areas and/or exposed soils caused by the installation of these practices must be stabilized within two days.

(Ord. 25-11. Passed 5-24-11.)

946.17 VIOLATIONS.

No person shall violate or cause or knowingly permit to be violated any of the provisions of this regulation, or fail to comply with any of such provisions or with any lawful requirements of any public authority made pursuant to this regulation, or knowingly use or cause or permit the use of any lands in violation of this regulation or in violation of any permit granted under this regulation.

(Ord. 25-11. Passed 5-24-11.)

946.18 APPEALS.

Any person aggrieved by any order, requirement, determination, or any other action or inaction by the City of Sheffield Lake in relation to this regulation may appeal to the court of common pleas. Such an appeal shall be made in conformity with the O.R.C. Written notice of appeal shall be served on the City of Sheffield Lake.

(Ord. 25-11. Passed 5-24-11.)

946.99 PENALTY.

(a) Any person, firm, entity or corporation; including but not limited to, the owner of the property, his agents and assigns, occupant, property manager, and any contractor or subcontractor who violates or fails to comply with any provision of this regulation is guilty of a misdemeanor of the third degree and shall be fined no more than five hundred dollars (\$500.00) or imprisoned for no more than sixty (60) days, or both, for each offense. A separate offense shall be deemed committed each day during or on which a violation or noncompliance occurs or continues.

(b) The imposition of any other penalties provided herein shall not preclude the City of Sheffield Lake from instituting an appropriate action or proceeding in a Court of proper jurisdiction to prevent an unlawful development, or to restrain, correct, or abate a violation, or to require compliance with the provisions of this regulation or other applicable laws, ordinances, rules, or regulations, or the orders of the City of Sheffield Lake.

(Ord. 25-11. Passed 5-24-11.)

Disclaimer: This Code of Ordinances and/or any other documents that appear on this site may not reflect the most current legislation adopted by the Municipality. American Legal Publishing provides these documents for informational purposes only. These documents should not be relied upon as the definitive authority for local legislation. Additionally, the formatting and pagination of the posted documents varies from the formatting and pagination of the official copy. The official printed copy of a Code of Ordinances should be consulted prior to any action being taken.

For further information regarding the official version of any of this Code of Ordinances or other documents posted on this site, please contact the Municipality directly or contact American Legal Publishing toll-free at 800-445-5588.

Detected legislative history

- Ordinances of Sheffield Lake, OH
- ORDINANCES OF THE CITY OF SHEFFIELD LAKE, OHIO
- ORDINANCE NO. 116-84
- ORDINANCES OF SHEFFIELD LAKE
- Ordinance, shall provide storm water management and water quality controls for the development of all subdivided lots
- ordinance with Inspection and Maintenance Agreements approved by the Service Director as detailed in Section 946
- order to protect the natural hydrology, hydroperiod, and wetland flora
- ordinary high water mark
- ord of the bridge for either the 100-year, 24-hour storm, or the 100-year flood elevation as determined by FEMA, whichever is more restrictive
- order to preserve floodplain storage volumes and thereby avoid increases in water surface elevations, any filling within floodplains approved by the City of Sheffield Lake must be com
- ording to one of the following methods:
- ords, or
- ordered to match CRWP's recommended BMP categories and additional description of the "drain time" for vegetated swales and filter strips has been added
- ording to the extended conveyance detention design drain time shall:
- ording to the flow through design drain time shall:
- ording to the flow through drain time
- effectiveness to those listed in Table 2
- order or greater or to a lake, and where the development area is less than 5 percent of the water area upstream of the development site, unless a Total Maximum Daily Load (TMDL) has i
- Ord. 25-11
- orded with the Lorain County Auditor and on all property deeds
- orded Inspection and Maintenance Agreement as specified in Section 946
- order, requirement, determination, or any other action or inaction by the City of Sheffield Lake in relation to this regulation may appeal to the court of common pleas
- ordinances, rules, or regulations, or the orders of the City of Sheffield Lake
- Ordinances and/or any other documents that appear on this site may not reflect the most current legislation adopted by the Municipality

- Ordinances should be consulted prior to any action being taken
 - Ordinances or other documents posted on this site, please contact the Municipality directly or contact American Legal Publishing toll-free at 800-445-5588
-

Imported automatically by MunicipalWiki. The original publisher remains the authoritative source pending legal normalization and verification.

Revision #1

Created 2026-07-18 21:29:09 UTC by MunicipalWiki Indexer

Updated 2026-07-18 21:29:09 UTC by MunicipalWiki Indexer